

Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at
http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name:	MIGRANT HEAD START PROGRAM - WATER
Water System Number:	CA5700702

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 4.30.2024 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name:	<u>Tom Berry</u>	
	Signature:	<u>[Signature]</u>	
	Title:	<u>Facilities Manager</u>	
	Phone Number:	<u>(530) 520-6339</u>	Date: <u>4-30-2024</u>

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

"Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

- Posted the CCR on the internet at http://www.ecenter.org
- Mailed the CCR to postal patrons within the service area (attach zip codes used)
- Advertised the availability of the CCR in news media (attach a copy of press release)
- Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
- Posted the CCR in public places (attach a list of locations) Parent Board
- Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
- Delivery to community organizations (attach a list of organizations)
- Other (attach a list of other methods used)

For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: http://

For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

2023 Consumer Confidence Report

Water System Name: MIGRANT HEAD START PROGRAM - WATER Report Date: April 2024

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2023.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: According to SWRCB records, this Source is Groundwater. This Assessment was done using the Default Groundwater System Method.

Your water comes from 2 source(s): WELL 01 (1988) and WELL 02 (2003)
and from 1 treated location(s): POST TREATMENT SAMPLE TAP

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board or city/county council meetings are currently not being held.

For more information about this report, or any questions relating to your drinking water, please call (530) 520-6339 and ask for Tom berry.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

pCi/L: picocuries per liter (a measure of radiation)

NTU: Nephelometric Turbidity Units

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, 6 and 7 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER							
Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	No. of Samples	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Copper (mg/L)	(2023)	5	0.22	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2022)	46	42 - 49	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2022)	183	157 - 208	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Arsenic (ug/L)	(2023)	2	n/a	10	0.004	Erosion of natural deposits; runoff from orchards, glass and electronics production wastes
Barium (mg/L)	(2021 - 2023)	0.15	0.13 - 0.16	1	2	Discharge from oil drilling wastes and from metal refineries; erosion of natural deposits

Chromium (ug/L)	(2021 - 2023)	14	13 - 14	50.0	n/a	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Fluoride (mg/L)	(2022)	0.1	n/a	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Hexavalent Chromium (ug/L)	(2018)	7.1	3.6 - 10.5		0.02	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits.
Nitrate as N (mg/L)	(2023)	1.6	1.3 - 1.9	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (mg/L)	(2022)	1.4	0.5 - 2.2	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Alpha (pCi/L)	(2017)	2.08	n/a	15	(0)	Erosion of natural deposits.

Table 4 - TREATED DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Hexavalent Chromium (ug/L)	(2016 - 2017)	ND	ND - ND	10	0.02	Discharge from electroplating factories, leather tanneries, wood preservation, chemical synthesis, refractory production, and textile manufacturing facilities; erosion of natural deposits.

Table 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2022)	40	36 - 44	500	n/a	Runoff/leaching from natural deposits; seawater influence
Specific Conductance (umhos/cm)	(2022)	575	512 - 637	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2022)	22.4	18.0 - 26.7	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2022)	340	310 - 370	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2022)	0.3	0.2 - 0.3	5	n/a	Soil runoff

Table 6 - DETECTION OF UNREGULATED CONTAMINANTS					
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Boron (mg/L)	(2022)	1.6	1.4 - 1.7	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.
Vanadium (ug/L)	(2021 - 2023)	7	6 - 7	50	Vanadium exposures resulted in developmental and reproductive effects in rats.

Table 7 - ADDITIONAL DETECTIONS					
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2022)	30	25 - 34	n/a	n/a

Magnesium (mg/L)	(2022)	27	23 - 30	n/a	n/a
pH (units)	(2022)	7.56	7.49 - 7.63	n/a	n/a
Alkalinity (mg/L)	(2022)	200	180 - 220	n/a	n/a
Aggressiveness Index	(2022)	11.8	11.7 - 11.8	n/a	n/a
Langelier Index	(2022)	-0.15	-0.2 - -0.09	n/a	n/a

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *E Center Head Start-Woodland* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

2023 Consumer Confidence Report Drinking Water Assessment Information

Assessment Information

A source water assessment was conducted for the WELL 01 of the MIGRANT HEAD START PROGRAM-WATER water system in December, 2002.

Acquiring Information

A copy of the complete assessment may be viewed at:
Yolo County Environmental Health Division
292 W. Beamer Street
Woodland CA 95695

E Center Head Start-Woodland Analytical Results By FGL - 2023

LEAD AND COPPER RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
Copper		mg/L		1.3	.3			0.215	5
Kitchen	CH 2378368-2	mg/L				2023-09-28	ND		
Ladies Restroom	CH 2378368-1	mg/L				2023-09-28	0.09		
Management Office	CH 2378368-4	mg/L				2023-09-28	0.33		
Mens Restroom	CH 2378368-3	mg/L				2023-09-28	0.05		
N/E Outside R/R	CH 2378368-5	mg/L				2023-09-28	0.10		

SAMPLING RESULTS FOR SODIUM AND HARDNESS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		mg/L		none	none			46	42 - 49
WELL 01 (1988)	CH 2272589-1	mg/L				2022-04-20	42		
WELL 02 (2003)	CH 2272588-1	mg/L				2022-04-20	49		
Hardness		mg/L		none	none			183	157 - 208
WELL 01 (1988)	CH 2272589-1	mg/L				2022-04-20	157		
WELL 02 (2003)	CH 2272588-1	mg/L				2022-04-20	208		

PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Arsenic		ug/L		10	0.004			2	2 - 2
WELL 01 (1988)	CH 2374018-1	ug/L				2023-06-15	2		
WELL 02 (2003)	CH 2390549-1	ug/L				2023-12-14	2		
WELL 02 (2003)	CH 2377673-1	ug/L				2023-09-08	2		
WELL 02 (2003)	CH 2374019-1	ug/L				2023-06-15	2		
WELL 02 (2003)	CH 2371975-1	ug/L				2023-03-30	2		
Barium		mg/L	2	1	2			0.15	0.13 - 0.16
WELL 01 (1988)	CH 2374018-1	mg/L				2023-06-15	0.16		
WELL 02 (2003)	CH 2173244-1	mg/L				2021-06-10	0.13		
Chromium		ug/L	100	50.0	n/a			14	13 - 14
WELL 01 (1988)	CH 2374018-1	ug/L				2023-06-15	13		
WELL 02 (2003)	CH 2173244-1	ug/L				2021-06-10	14		
Fluoride		mg/L		2	1			0.1	0.1 - 0.1
WELL 01 (1988)	CH 2272589-1	mg/L				2022-04-20	0.1		
WELL 02 (2003)	CH 2272588-1	mg/L				2022-04-20	0.1		
Hexavalent Chromium		ug/L			0.02			7.1	3.6 - 10.5
WELL 01 (1988)	CH 1871189-1	ug/L				2018-02-19	10.5		
WELL 01 (1988)	CH 1870731-1	ug/L				2018-01-30	3.6		
Nitrate as N		mg/L		10	10			1.6	1.3 - 1.9
WELL 01 (1988)	CH 2374018-1	mg/L				2023-06-15	1.3		
WELL 02 (2003)	CH 2374019-1	mg/L				2023-06-15	1.9		
Nitrate + Nitrite as N		mg/L		10	10			1.4	0.5 - 2.2
WELL 01 (1988)	CH 2272589-1	mg/L				2022-04-20	0.5		
WELL 02 (2003)	CH 2272588-1	mg/L				2022-04-20	2.2		
Gross Alpha		pCi/L		15	(0)			2.08	2.08 - 2.08
WELL 01 (1988)	CH 1777524-1	pCi/L				2017-08-31	2.08		

TREATED PRIMARY DRINKING WATER STANDARDS (PDWS)									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Hexavalent Chromium		ug/L		10	0.02			ND	ND - ND
POST TREATMENT SAMPLE TAP	CH 1790385-1	ug/L				2017-12-28	ND		
POST TREATMENT SAMPLE TAP	CH 1779811-1	ug/L				2017-11-29	ND		

POST TREATMENT SAMPLE TAP	CH 1778935-1	ug/L				2017-10-16	ND		
POST TREATMENT SAMPLE TAP	CH 1777777-1	ug/L				2017-09-18	ND		
POST TREATMENT SAMPLE TAP	CH 1777518-1	ug/L				2017-08-31	ND		
POST TREATMENT SAMPLE TAP	CH 1776175-1	ug/L				2017-07-26	ND		
POST TREATMENT SAMPLE TAP	CH 1773220-1	ug/L				2017-05-15	ND		
POST TREATMENT SAMPLE TAP	CH 1772259-1	ug/L				2017-04-17	ND		
POST TREATMENT SAMPLE TAP	CH 1679256-1	ug/L				2016-10-31	ND		

SECONDARY DRINKING WATER STANDARDS (SDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		mg/L		500	n/a			40	36 - 44
WELL 01 (1988)	CH 2272589-1	mg/L				2022-04-20	36		
WELL 02 (2003)	CH 2272588-1	mg/L				2022-04-20	44		
Specific Conductance		umhos/cm		1600	n/a			575	512 - 637
WELL 01 (1988)	CH 2272589-1	umhos/cm				2022-04-20	512		
WELL 02 (2003)	CH 2272588-1	umhos/cm				2022-04-20	637		
Sulfate		mg/L		500	n/a			22.4	18.0 - 26.7
WELL 01 (1988)	CH 2272589-1	mg/L				2022-04-20	18.0		
WELL 02 (2003)	CH 2272588-1	mg/L				2022-04-20	26.7		
Total Dissolved Solids		mg/L		1000	n/a			340	310 - 370
WELL 01 (1988)	CH 2272589-1	mg/L				2022-04-20	310		
WELL 02 (2003)	CH 2272588-1	mg/L				2022-04-20	370		
Turbidity		NTU		5	n/a			0.3	0.2 - 0.3
WELL 01 (1988)	CH 2272589-1	NTU				2022-04-20	0.3		
WELL 02 (2003)	CH 2272588-1	NTU				2022-04-20	0.2		

UNREGULATED CONTAMINANTS

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Boron		mg/L		NS	n/a			1.6	1.4 - 1.7
WELL 01 (1988)	CH 2272589-1	mg/L				2022-04-20	1.4		
WELL 02 (2003)	CH 2272588-1	mg/L				2022-04-20	1.7		
Vanadium		ug/L		NS	n/a			7	6 - 7
WELL 01 (1988)	CH 2374018-1	ug/L				2023-06-15	6		
WELL 02 (2003)	CH 2173244-1	ug/L				2021-06-10	7		

ADDITIONAL DETECTIONS

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Calcium		mg/L			n/a			30	25 - 34
WELL 01 (1988)	CH 2272589-1	mg/L				2022-04-20	25		
WELL 02 (2003)	CH 2272588-1	mg/L				2022-04-20	34		
Magnesium		mg/L			n/a			27	23 - 30
WELL 01 (1988)	CH 2272589-1	mg/L				2022-04-20	23		
WELL 02 (2003)	CH 2272588-1	mg/L				2022-04-20	30		
pH		units			n/a			7.56	7.49 - 7.63
WELL 01 (1988)	CH 2272589-1	units				2022-04-20	7.63		
WELL 02 (2003)	CH 2272588-1	units				2022-04-20	7.49		
Alkalinity		mg/L			n/a			200	180 - 220
WELL 01 (1988)	CH 2272589-1	mg/L				2022-04-20	180		
WELL 02 (2003)	CH 2272588-1	mg/L				2022-04-20	220		
Aggressiveness Index					n/a			11.8	11.7 - 11.8
WELL 01 (1988)	CH 2272589-1					2022-04-20	11.7		
WELL 02 (2003)	CH 2272588-1					2022-04-20	11.8		
Langelier Index					n/a			-0.15	-0.2 - -0.09
WELL 01 (1988)	CH 2272589-1					2022-04-20	-0.2		
WELL 02 (2003)	CH 2272588-1					2022-04-20	-0.09		

E Center Head Start-Woodland CCR Login Linkage - 2023

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
DST_LCR	CH 2378368-2	2023-09-28	Metals, Total	Kitchen	Lead & Copper Monitoring
	CH 2378368-1	2023-09-28	Metals, Total	Ladies Restroom	Lead & Copper Monitoring
	CH 2378368-4	2023-09-28	Metals, Total	Management Office	Lead & Copper Monitoring
	CH 2378368-3	2023-09-28	Metals, Total	Mens Restroom	Lead & Copper Monitoring
	CH 2378368-5	2023-09-28	Metals, Total	N/E Outside R/R	Lead & Copper Monitoring
Finished Water	CH 1679256-1	2016-10-31	Wet Chemistry	POST TREATMENT SAMPLE TAP	E Center Head Start-Woodland
FINISHED H2O	CH 1772259-1	2017-04-17	Wet Chemistry	POST TREATMENT SAMPLE TAP	Chrome 6 Monitoring
	CH 1773220-1	2017-05-15	Wet Chemistry	POST TREATMENT SAMPLE TAP	Chrome 6 Monitoring
	CH 1776175-1	2017-07-26	Wet Chemistry	POST TREATMENT SAMPLE TAP	Chrome 6 Monitoring
	CH 1777518-1	2017-08-31	Wet Chemistry	POST TREATMENT SAMPLE TAP	Cr VI Monitoring
	CH 1777777-1	2017-09-18	Wet Chemistry	POST TREATMENT SAMPLE TAP	Cr VI Monitoring
	CH 1778935-1	2017-10-16	Wet Chemistry	POST TREATMENT SAMPLE TAP	Cr VI Monitoring
	CH 1779811-1	2017-11-29		POST TREATMENT SAMPLE TAP	Cr VI Monitoring
	CH 1790385-1	2017-12-28	Wet Chemistry	POST TREATMENT SAMPLE TAP	Cr VI Monitoring
	Womens RR	CH 2370346-1	2023-01-16	Coliform	ROUTINE-WOMEN'S RESTROOM
CH 2371242-1		2023-02-23	Coliform	ROUTINE-WOMEN'S RESTROOM	Drinking Water Monitoring
CH 2371974-1		2023-03-30	Coliform	ROUTINE-WOMEN'S RESTROOM	Drinking Water Monitoring
CH 2372848-1		2023-04-27	Coliform	ROUTINE-WOMEN'S RESTROOM	Drinking Water Monitoring
CH 2373444-1		2023-05-23	Coliform	ROUTINE-WOMEN'S RESTROOM	Drinking Water Monitoring
CH 2373915-1		2023-06-15	Coliform	ROUTINE-WOMEN'S RESTROOM	Drinking Water Monitoring
CH 2375926-1		2023-07-26	Coliform	ROUTINE-WOMEN'S RESTROOM	Drinking Water Monitoring
CH 2377111-1		2023-08-24	Coliform	ROUTINE-WOMEN'S RESTROOM	Drinking Water Monitoring
CH 2377624-1		2023-09-08	Coliform	ROUTINE-WOMEN'S RESTROOM	Drinking Water Monitoring
CH 2378661-1		2023-10-12	Coliform	ROUTINE-WOMEN'S RESTROOM	Drinking Water Monitoring
CH 2379654-1		2023-11-09	Coliform	ROUTINE-WOMEN'S RESTROOM	Drinking Water Monitoring
CH 2390826-1		2023-12-28	Coliform	ROUTINE-WOMEN'S RESTROOM	Drinking Water Monitoring
WELL01		CH 1472985-1	2014-06-05	Metals, Total	WELL 01 (1988)
	CH 1777524-1	2017-08-31	Radio Chemistry	WELL 01 (1988)	Well 01 - Radio & Asbestos Monitoring
	CH 1870731-1	2018-01-30	Wet Chemistry	WELL 01 (1988)	MIGRANT HEAD START PROGRAM - WATER
	CH 1871189-1	2018-02-19	Wet Chemistry	WELL 01 (1988)	Cr VI Monitoring
	CH 2272589-1	2022-04-20	Wet Chemistry	WELL 01 (1988)	Well 01- Water Quality - 2
	CH 2272589-1	2022-04-20	General Mineral	WELL 01 (1988)	Well 01- Water Quality - 2
	CH 2374018-1	2023-06-15	Metals, Total	WELL 01 (1988)	Well 01 - Water Quality Monitoring
	CH 2374018-1	2023-06-15	Wet Chemistry	WELL 01 (1988)	Well 01 - Water Quality Monitoring
	WELL02	CH 2173244-1	2021-06-10	Metals, Total	WELL 02 (2003)
CH 2272588-1		2022-04-20	General Mineral	WELL 02 (2003)	Well 02 - Water Quality - 2
CH 2272588-1		2022-04-20	Wet Chemistry	WELL 02 (2003)	Well 02 - Water Quality - 2
CH 2371975-1		2023-03-30	Metals, Total	WELL 02 (2003)	Well 02 - Water Quality
CH 2374019-1		2023-06-15	Wet Chemistry	WELL 02 (2003)	Well 02 - Water Quality
CH 2374019-1		2023-06-15	Metals, Total	WELL 02 (2003)	Well 02 - Water Quality
CH 2377673-1		2023-09-08	Metals, Total	WELL 02 (2003)	Well 02 - Water Quality
CH 2390549-1		2023-12-14	Metals, Total	WELL 02 (2003)	Well 02 - Water Quality